



Electrical Standard of Work

Electrical Panels: Square D Disconnects and QOB Electrical Panels and bolt-in-breakers will be used at all times.

RV Pedestals: Shall be Midwest Cat# U075CB6010 or U075CP6010 (No Exceptions)

Lighting Fixtures: Lighting fixtures will be 5K color for Exterior applications, 4K for Office areas and 5K for Barns and Arenas. Fixture brand and style will be approved by Management, to maintain the standard of quality and appearance of the property.

Devices: No device shall be rated less than 20 amps. All switches, outlets, GFCI's, etc. shall be rated 20 amps or greater.

Conductors: Copper wire **SHALL** be used at all times.

Conduit: Conduit shall be used for all electrical installations. **Exception:** MC and AC Can be used if installed in a drop or hard ceiling or in walls where it is protected from physical damage.

NEC Compliance: All electrical installations shall be installed in compliance with the National Electrical Code and the Authority Having Jurisdiction.

Exceptions: Any exceptions to these electrical standards shall be discussed with the Electrical Department Management Staff listed below.

Assistant Electrical Manager

George Merritt

813-363-4045

Electrical Manager

John Schuiteboer

813-363-5514